

**Illinois Environmental Protection Agency
Division of Public Water Supplies
Restricted Status / Critical Review Combined List**

January 2017

| SYSTEM NAME | SYSTEM ID | RS/CR | EPA REGION | NATURE OF PROBLEM | POPULATION SERVED | LISTING DATE |
|---|-----------|-------|------------|---|-------------------|--------------|
| ANDALUSIA (upper elevation area) | IL1610050 | RS | 1 | LOW SYSTEM PRESSURE | 1050 | 10/1/2003 |
| ANDOVER | IL0730100 | RS | 1 | NO BACKUP SOURCE | 600 | 3/24/2016 |
| ANNA | IL1810050 | CR | 7 | INADEQUATE TREATMENT CAPACITY | 5043 | 7/1/2011 |
| ANNA - JONESBORO WATER COMMISSION | IL1815050 | CR | 7 | INADEQUATE TREATMENT CAPACITY | 36 | 7/1/2011 |
| AQUA ILLINOIS - CRYSTAL CLEAR WATER CO. | IL1115150 | RS | 2 | NO EMERGENCY POWER & NO PRESSURE TANK | 855 | 9/16/1988 |
| AQUA ILLINOIS - NUNDA | IL1115600 | RS | 2 | INADEQUATE PRESSURE TANK | 570 | 4/1/2015 |
| AVANTARA LONG GROVE | IL0971110 | RS | 2 | INADEQUATE PRESSURE TANK | 200 | 12/1/2003 |
| BAHL WATER CORP | IL0855200 | RS | 1 | NO ELEVATED OR GROUND STORAGE | 700 | 12/15/1993 |
| BEASON CHESTNUT PWD | IL1075150 | CR | 5 | INADEQUATE SOURCE CAPACITY & INADEQUATE PRESSURE TANK | 435 | 6/15/2004 |
| BEVERLY HILLSDALE ESTATES, LLC | IL1615530 | RS | 1 | INADEQUATE PRESSURE TANK | 63 | 3/18/1983 |
| BILL-MAR HEIGHTS MHP | IL2015345 | RS | 1 | INADEQUATE PRESSURE TANK | 160 | 3/18/1983 |
| BLUE MOUND | IL1150100 | RS | 4 | NITRATE MCL VIOLATION | 1300 | 8/3/2016 |
| BUFFALO HOLLOW FARMS WATER ASSOCIATION | IL1430080 | RS | 5 | INADEQUATE PRESSURE TANK | 45 | 6/16/2008 |
| CANTON | IL0570250 | CR | 5 | INADEQUATE TREATMENT CAPACITY | 13932 | 3/15/2007 |
| CAPRON MHP | IL0075105 | RS | 1 | INADEQUATE PRESSURE TANK | 98 | 3/18/1983 |
| CARBON HILL* | IL0630100 | CR | 2 | INADEQUATE TREATMENT CAPACITY | 392 | 12/14/2016 |
| CENTURY PINES APARTMENTS | IL0150020 | RS | 1 | INADEQUATE PRESSURE TANK | 50 | 12/14/1990 |
| CHAIN-O-LAKES MHP | IL0975165 | RS | 2 | INADEQUATE PRESSURE TANK | 81 | 12/15/1989 |
| CLARKS MHP | IL2015425 | RS | 1 | INADEQUATE PRESSURE TANK | 80 | 12/16/1991 |
| COAL CITY* | IL0630200 | CR | 2 | INADEQUATE TREATMENT CAPACITY | 5587 | 12/14/2016 |
| COUNTRY ACRES MHP (LaSalle County) | IL0995365 | RS | 1 | RADIUM MCL VIOLATION | 295 | 5/4/2016 |
| COYNE CNTR COOP | IL1615150 | RS | 1 | INADEQUATE PRESSURE TANK | 150 | 12/15/1997 |
| CRISWELL COURT MHP | IL1975105 | RS | 2 | INADEQUATE PRESSURE TANK | 136 | 12/15/1989 |
| DATTIS MHP | IL0995225 | RS | 1 | INADEQUATE PRESSURE TANK | 115 | 3/18/1983 |
| DAYSRING BIBLE COLLEGE | IL0977189 | RS | 2 | INADEQUATE PRESSURE TANK | 60 | 6/15/1988 |

**Illinois Environmental Protection Agency
Division of Public Water Supplies
Restricted Status / Critical Review Combined List**

January 2017

| SYSTEM NAME | SYSTEM ID | RS/CR | EPA REGION | NATURE OF PROBLEM | POPULATION SERVED | LISTING DATE |
|--|-----------|-------|------------|---|-------------------|--------------|
| DES PLAINES MHP | IL0317775 | RS | 2 | INADEQUATE SOURCE CAPACITY & INADEQUATE PRESSURE TANK | 580 | 3/16/1984 |
| EAST END WATER ASSOCIATION | IL1610140 | RS | 1 | INADEQUATE PRESSURE TANK | 40 | 3/15/2002 |
| EAST MORELAND WATER ASSOCIATION | IL1975600 | RS | 2 | NO ELEVATED OR GROUND STORAGE | 1055 | 9/9/2016 |
| EDELSTEIN WATER COOPERATIVE | IL1435150 | RS | 5 | INADEQUATE GROUND STORAGE & NO EMERGENCY POWER | 125 | 1/1/2015 |
| EHLERS MHP | IL0195645 | RS | 4 | INADEQUATE PRESSURE TANK | 112 | 12/17/1982 |
| ELIZABETH (upper elevation area) | IL0850150 | RS | 1 | LOW SYSTEM PRESSURE | 675 | 6/15/1999 |
| ERIE | IL1950200 | RS | 1 | NITRATE MCL VIOLATION | 1600 | 2/8/2016 |
| EXETER - MERRITT WATER COOP | IL1710010 | RS | 5 | INADEQUATE STORAGE CAPACITY | 765 | 10/1/2013 |
| FAMILY MANUFACTURED HOME COMMUNITY, LLC | IL2015125 | RS | 1 | INADEQUATE PRESSURE TANK | 240 | 12/17/1982 |
| FOUNTAIN VALLEY MHP | IL0195945 | RS | 4 | ARSENIC MCL VIOLATION | 375 | 8/2/2016 |
| FOUR STAR CAMPGROUND | IL0990060 | RS | 1 | INADEQUATE PRESSURE TANK | 150 | 6/15/1999 |
| FOX LAWN HOMEOWNERS WATER ASSOCIATION* | IL0935150 | RS | 2 | RADIUM MCL VIOLATION | 238 | 8/2/2016 |
| GOODFIELD | IL2034450 | RS | 1 | HALOACETIC ACIDS MCL VIOLATION | 700 | 8/11/2016 |
| GRANDVIEW MHP | IL1795365 | RS | 5 | INADEQUATE PRESSURE TANK | 300 | 3/18/1983 |
| GREAT OAKS AND BEACON HILLS APARTMENTS | IL2015488 | RS | 1 | NO ELEVATED OR GROUND STORAGE | 1816 | 12/17/1982 |
| GREEN MEADOWS ESTATES OF ROCKFORD LLC | IL2015495 | RS | 1 | INADEQUATE GROUND STORAGE & INADEQUATE PRESSURE TANK | 970 | 6/15/2012 |
| GREENFIELD | IL0610150 | RS | 6 | HALOACETIC ACIDS MCL VIOLATION | 1200 | 1/5/2016 |
| HAMPSHIRE (does not include the Special Services Area (TP04))* | IL0890450 | RS | 2 | RADIUM MCL VIOLATION | 5563 | 11/30/2016 |
| HAMPTON | IL1610300 | RS | 1 | HALOACETIC ACIDS MCL VIOLATION | 1800 | 8/25/2016 |
| HIATTS HIDEAWAY MHP | IL1795495 | RS | 5 | INADEQUATE PRESSURE TANK | 65 | 9/15/1989 |
| HIGHLAND SUBDIVISON | IL0895530 | RS | 2 | INADEQUATE PRESSURE TANK | 50 | 9/16/1983 |

**Illinois Environmental Protection Agency
Division of Public Water Supplies
Restricted Status / Critical Review Combined List**

January 2017

| SYSTEM NAME | SYSTEM ID | RS/CR | EPA REGION | NATURE OF PROBLEM | POPULATION SERVED | LISTING DATE |
|-------------------------------------|-----------|-------|------------|---|-------------------|--------------|
| HILLVIEW SUBDIVISION | IL1975800 | RS | 2 | INADEQUATE PRESSURE TANK | 100 | 3/15/1985 |
| HOLLY HOCK HILL MHP | IL0975245 | RS | 2 | INADEQUATE PRESSURE TANK | 52 | 12/16/1983 |
| HONEYCUTT HILL MHP LLC | IL1955225 | RS | 1 | INADEQUATE PRESSURE TANK | 75 | 9/17/1982 |
| IL AMERICAN - RANSOM | IL0990900 | RS | 1 | RADIUM MCL VIOLATION | 483 | 6/15/2012 |
| INGALLS PARK SUBDIVISION | IL1975880 | RS | 2 | NO ELEVATED OR GROUND STORAGE | 744 | 9/16/1983 |
| JONESBORO PWS | IL1810250 | CR | 7 | INADEQUATE TREATMENT CAPACITY | 1912 | 7/1/2011 |
| LAHARPE | IL0670450 | RS | 5 | HALOACETIC ACIDS MCL VIOLATION | 1235 | 8/4/2016 |
| LARSON COURT APARTMENTS | IL1615728 | RS | 1 | INADEQUATE PRESSURE TANK | 58 | 1/14/1982 |
| LASALLE | IL0990300 | CR | 1 | INADEQUATE SOURCE CAPACITY & INADEQUATE TREATMENT CAPACITY | 9700 | 11/1/2004 |
| LEGEND LAKES WATER ASSOCIATION | IL2015300 | RS | 1 | INADEQUATE PRESSURE TANK | 283 | 3/14/1991 |
| LIBERTY PARK HOMEOWNERS ASSOCIATION | IL0435600 | RS | 2 | INADEQUATE GROUND STORAGE CAPACITY | 837 | 9/17/1992 |
| LICK CREEK PWD | IL1815100 | CR | 7 | INADEQUATE TREATMENT CAPACITY | 2020 | 7/1/2011 |
| LIMA | IL0010400 | RS | 5 | INADEQUATE SOURCE CAPACITY & NITRATE MCL VIOLATION | 163 | 5/4/2016 |
| LINDENWOOD WATER ASSOCIATION | IL1415300 | RS | 1 | INADEQUATE PRESSURE TANK | 50 | 1/13/1982 |
| LISBON NORTH, INC. | IL0631000 | RS | 2 | INADEQUATE PRESSURE TANK | 30 | 9/14/1990 |
| LYNNWOOD WATER CORPORATION | IL0995336 | RS | 1 | INADEQUATE PRESSURE TANK | 110 | 3/18/1983 |
| MACOMB* | IL1090350 | CR | 5 | INADEQUATE CLARIFIER CAPACITY | 11309 | 12/14/2016 |
| MAEYSTOWN | IL1330200 | RS | 6 | NITRATE MCL VIOLATION | 157 | 6/15/2012 |
| MALTA | IL0370350 | RS | 1 | NO AUTO-START GENERATOR & INADEQUATE HIGH SERVICE PUMP CAPACITY | 1175 | 6/15/2012 |
| MANCUSO VILLAGE PARK MHP | IL2015545 | RS | 1 | INADEQUATE PRESSURE TANK | 500 | 6/18/1982 |
| MANTENO MHP | IL0915385 | RS | 2 | INADEQUATE PRESSURE TANK | 144 | 12/14/1990 |
| MASON CITY | IL1250350 | CR | 5 | INADEQUATE STORAGE TANK | 2558 | 1/1/2006 |
| MITCHELLSVILLE PWD | IL1655200 | RS | 7 | LOW SYSTEM PRESSURE | 1989 | 10/1/2012 |

**Illinois Environmental Protection Agency
Division of Public Water Supplies
Restricted Status / Critical Review Combined List**

January 2017

| SYSTEM NAME | SYSTEM ID | RS/CR | EPA REGION | NATURE OF PROBLEM | POPULATION SERVED | LISTING DATE |
|--|-----------|-------|---------------|---|----------------------|-----------------|
| MORNINGSIDE MOBILE ESTATES MHP | IL1075145 | RS | 5 | NITRATE MCL VIOLATION | 75 | 8/11/2016 |
| MOUND PWD | IL1635050 | CR | 6 | INADEQUATE PLANT CAPACITY | 2200 | 6/17/1996 |
| MULBERRY GROVE | IL0050100 | RS | 6 | HALOACETIC ACIDS MCL VIOLATION | 725 | 1/5/2016 |
| NEW SALEM PWD | IL1090010 | RS | 5 | TOTAL TRIHOLMETHANES MCL VIOLATION | 225 | 4/1/2015 |
| NORTH TAZEWELL PWD | IL1795780 | RS | 5 | HALOACETIC ACIDS MCL VIOLATION; TOTAL TRHALOMETHANES MCL VIOLATION | 8300 | 2/8/2016 |
| NORTHWEST BELMONT IMPROVEMENT ASSN | IL0435900 | RS | 2 | INADEQUATE PRESSURE TANK | 75 | 9/29/1981 |
| OAK RIDGE SD | IL2035300 | RS | 1 | INADEQUATE PRESSURE TANK | 240 | 3/20/1981 |
| OSCO MUTUAL WATER SUPPLY COMPANY, INC. | IL0735200 | RS | 1 | INADEQUATE PUMP CAPACITY | 115 | 12/15/1989 |
| PARADISE MANOR MHP | IL1617665 | RS | 1 | INADEQUATE PRESSURE TANK | 193 | 2/19/1982 |
| PARK MEADOWLAND WEST MHP | IL0075235 | RS | 1 | INADEQUATE PRESSURE TANK | 100 | 3/18/1982 |
| PAULS MHP | IL0975485 | RS | 2 | INADEQUATE PRESSURE TANK | 38 | 12/16/1983 |
| PORTS SULLIVAN LAKE OWNERS ASSOCIATION | IL0971160 | RS | 2 | INADEQUATE PRESSURE TANK | 293 | 6/15/1999 |
| PRAIRIE ROAD PUMP ASSOCIATION | IL2015100 | RS | 1 | INADEQUATE PRESSURE TANK | 150 | 1/1/2006 |
| QUINCY | IL0010650 | CR | 5 | INADEQUATE CLARIFIER CAPACITY | 45000 | 8/3/2016 |
| RAINBOW LANE MHP | IL2015645 | RS | 1 | INADEQUATE PRESSURE TANK | 85 | 6/17/1983 |
| RIVERVIEW MHP (HENRY COUNTY) | IL0735425 | RS | 1 | INADEQUATE PRESSURE TANK | 65 | 9/17/1982 |
| ROCHELLE | IL1410500 | RS | 1 | RADIUM MCL VIOLATION | 9850 | 5/4/2016 |
| ROCKLAND MHP | IL0975585 | RS | 2 | INADEQUATE PRESSURE TANK | 165 | 12/16/1983 |
| ROLLING GREEN ESTATES MHP | IL1415245 | RS | 1 | INADEQUATE PRESSURE TANK | 191 | 6/14/1985 |
| ROYAL OAKS MHP | IL1115145 | RS | 2 | INADEQUATE PRESSURE TANK | 114 | 6/17/1983 |
| SCALES MOUND | IL0850400 | RS | 1 | LOW SYSTEM PRESSURE (at elev. above 990 ft. MSL) | 401 | 9/15/1997 |
| SHANGRI-LA MHP | IL1415285 | RS | 1 | INADEQUATE PRESSURE TANK | 444 | 9/16/1983 |
| SHANNON* | IL0150300 | RS | 1 | RADIUM MCL VIOLATION | 758 | 8/4/2016 |
| SHAWNEE VALLEY PWD | IL1815550 | RS | 7 | TOTAL TRIHOLMETHANES MCL VIOLATION | 907 | 8/25/2016 |

**Illinois Environmental Protection Agency
Division of Public Water Supplies
Restricted Status / Critical Review Combined List**

January 2017

| SYSTEM NAME | SYSTEM ID | RS/CR | EPA REGION | NATURE OF PROBLEM | POPULATION SERVED | LISTING DATE |
|---|-----------|-------|---------------|--|----------------------|-----------------|
| SHAWNEE VALLEY PWD | IL1815550 | CR | 7 | INADEQUATE TREATMENT CAPACITY | 907 | 7/1/2011 |
| SHAWNITA TRC WATER ASSOCIATION | IL1977690 | RS | 2 | INADEQUATE PRESSURE TANK | 135 | 9/17/1992 |
| SILVIS HEIGHTS WATER CORP | IL1615750 | RS | 1 | NO EMERGENCY GENERATOR | 1600 | 12/1/2003 |
| SIX OAKS MHP | IL2015685 | RS | 1 | INADEQUATE PRESSURE TANK | 48 | 6/18/1982 |
| SOUTH SANGAMON WATER COMMISSION | IL1670080 | RS | 5 | NO ELEVATED OR PRESSURE STORAGE | 104 | 4/1/2015 |
| SPARTA* | IL1570600 | RS | 6 | HALOACETIC ACIDS MCL VIOLATION | 5153 | 12/27/2016 |
| STEPHENSON MOBILE ESTATES | IL1775235 | RS | 1 | INADEQUATE PRESSURE TANK | 223 | 6/17/1983 |
| SUBURBAN APARTMENTS (DE KALB UNIV DVL) | IL0375148 | RS | 1 | INADEQUATE PRESSURE TANK | 1050 | 12/16/1992 |
| SUBURBAN HEIGHTS SUBDIVISION | IL1615800 | RS | 1 | INADEQUATE PRESSURE TANK | 82 | 12/16/1983 |
| SUMNER | IL1010300 | RS | 7 | LOW SYSTEM PRESSURE (areas served by undersized water mains) | 1108 | 12/13/1985 |
| SUNNY HILLS ESTATES SUBDIVISION | IL0735300 | RS | 1 | INADEQUATE PRESSURE TANK | 525 | 6/15/2000 |
| SWEDONA WATER ASSOCIATION | IL1315200 | RS | 1 | INADEQUATE PRESSURE TANK | 157 | 6/15/1990 |
| SYLVAN LAKE 1ST SUBDIVISION | IL0977100 | RS | 2 | INADEQUATE PRESSURE TANK | 210 | 6/14/1991 |
| TIMBER RIDGE MOBILE ESTATES | IL1775255 | RS | 1 | INADEQUATE PRESSURE TANK | 150 | 6/17/1996 |
| TOWNERS SUBDIVISION | IL0977250 | RS | 2 | INADEQUATE PRESSURE TANK | 204 | 1/14/1982 |
| TRIANGLE MHP | IL0195925 | RS | 1 | ARSENIC MCL VIOLATION | 90 | 6/15/2012 |
| UTL INC - LAKE HOLIDAY | IL0995200 | RS | 1 | INADEQUATE TREATMENT CAPACITY | 6479 | 4/1/2015 |
| UTL INC - LAKE WILDWOOD UTILITIES CORP | IL1235200 | RS | 1 | INADEQUATE GROUND STORAGE & HIGH SERVICE PUMP CAPACITY | 950 | 10/22/2015 |
| UTL INC - WALK-UP WOODS WATER COMPANY | IL1115800 | RS | 2 | NO ELEVATED OR GROUND STORAGE | 781 | 12/17/1982 |
| VALLEY VIEW SUBDIVISION (WOODFORD COUNTY) | IL2030010 | RS | 1 | INADEQUATE PRESSURE TANK | 100 | 6/15/2012 |
| VIETZEN MHP | IL0437245 | RS | 2 | INADEQUATE PRESSURE TANK | 150 | 6/17/1983 |
| WELDON | IL0390350 | RS | 4 | ARSENIC MCL VIOLATION | 450 | 8/2/2016 |
| WHITE HALL | IL0610400 | CR | 6 | INADEQUATE STORAGE CAPACITY | 2900 | 10/1/2012 |
| WILDLIFE MHP | IL0995425 | RS | 1 | INADEQUATE PRESSURE TANK | 73 | 9/17/1982 |

**Illinois Environmental Protection Agency
 Division of Public Water Supplies
 Restricted Status / Critical Review Combined List**

January 2017

| SYSTEM NAME | SYSTEM ID | RS/CR | EPA REGION | NATURE OF PROBLEM | POPULATION SERVED | LISTING DATE |
|----------------------|------------------|--------------|-----------------------|---|------------------------------|-------------------------|
| WILLOWAY TERRACE MHP | IL0317595 | RS | 2 | NO ELEVATED OR GROUND STORAGE & INADEQUATE SOURCE CAPACITY | 900 | 6/15/1984 |
| WITT | IL1350850 | CR | 5 | INADEQUATE TREATMENT CAPACITY | 991 | 3/17/2008 |

WATER SYSTEMS REMOVED FROM PREVIOUS LIST

AIR VIEW MHP
 EXPRESSWAY MHP
 HOMER
 OAK GROVE MHP - ROCK ISLAND COUNTY

***WATER SYSTEMS ADDED**

CARBON HILL
 COAL CITY
 HAMPSHIRE
 MACOMB
 SPARTA